



NORTH DAKOTA  
PETROLEUM  
COUNCIL

*We keep North Dakota going strong*



# **BKN QUALITY & SAFETY INITIATIVE**

**NDPC Bakken Crude Characterization Task Force  
Presentation of Preliminary Results**

**Williston Basin Petroleum Conference  
Bismarck, North Dakota - May 20, 2014**

[www.ndoil.org](http://www.ndoil.org)



NORTH DAKOTA  
PETROLEUM  
COUNCIL



# Key Findings

- Bakken Quality is very consistent
  - Typical Class 3 Flammable Liquid
  - Both well-to-well and throughout the supply chain
  - Little variation throughout entire basin
  - Shows no “spiking” with NGL’s before rail shipment
  - No practical changes in quality during transit
- Produced for over 60 years
  - Recently passed one billion barrel mark
  - Moved by rail, pipeline, truck
  - No corrosion noted by any stakeholder





# Key Findings (continued)

- Very desirable to refiners
  - High transportation fuel yield (gasoline, jet fuel and diesel)
  - Low Metals/ConCarbon contents
- PHMSA mandated IBP test (D86) appears not to be the optimal test method for PG determination
  - Significant variability between labs on same sample
  - Not designed for wide boiling range material like crude oil
  - Other groups, including API, are working on recommendations





# Why study was initiated?

- Address the following:
  - Volatility?
  - Flammable Liquid or Flammable Gas?
  - Presence of subsidiary hazard?
    - Corrosive?
  - **All Analyses conclude Bakken is properly Classified as a Flammable Liquid**
  - **Three studies all in agreement: NDPC, AFPM and Transport Canada**





# Project Contractors

- Turner, Mason & Company – Overall Project Coordinator
  - Internationally recognized refining consultants
  - 43 years in business
  - TM&C staff supplemented by outside expertise
- SGS - Sampling and Testing Contractor
  - World leading testing and inspection company
  - Over 135 years in business
  - Utilized both local and USGC laboratories
- Overall cost \$400,000






# Project Overview

- NDPC commissioned comprehensive sampling and testing program to establish quality baseline
- BKN crude sampled from both well and rail sites
  - 15 well sites and 7 rail-loading terminals
  - Well sites represent producers with over 50% of total ND production
  - Rail sites represent about 50% of total ND rail capacity
  - Significant geographic dispersion for both well and rail sites
- Sampling initiated on 3/25 and completed on 4/24
  - 7 samples at each site
  - Initial samples at well sites included both top and bottom
- Sampling Complete; Testing over 95% complete
  - 152 total samples – 103 from well sites; 49 from rail sites
- Supplemental data provided by member companies







# Well Locations

**Antelope**

API	44.3
D86 IBP	95.6
Vapor P	12.97
C2-C4s	7.24

**West Williams (2 Sites)**

API	38.7	40.0
D86 IBP	99.5	100.0
Vapor P	11.72	11.76
C2-C4s	5.39	5.60

**North Tioga**

API	42.0
D86 IBP	97.6
Vapor P	11.10
C2-C4s	7.34

**Ross**

API	38.9
D86 IBP	98.5
Vapor P	11.47
C2-C4s	6.03

**South Tioga**

API	42.9
D86 IBP	98.6
Vapor P	11.27
C2-C4s	5.88

**New Town**

API	37.8
D86 IBP	102.0
Vapor P	10.75
C2-C4s	4.22

**Elm Coulee**

API	42.8
D86 IBP	97.8
Vapor P	12.48
C2-C4s	6.01

**North McKenzie**

API	41.0
D86 IBP	101.4
Vapor P	11.81
C2-C4	4.70

**Charlson**

API	43.0
D86 IBP	97.3
Vapor P	12.42
C2-C4s	6.58

**Sanish/Parshall (2 Sites)**

API	41.9	40.2
D86 IBP	97.6	98.2
Vapor P	12.67	12.63
C2-C4s	6.21	5.78

**Parshall Field**

API	40.7
D86 IBP	99.5
Vapor P	12.47
C2-C4s	5.85

	Min	Avg	Max
API	37.6	40.7	44.3
D86 IBP	95.6	99.1	102.0
Vapor P	10.61	11.78	12.97
C2-C4s%	4.16	5.69	7.34


**Western Dunn**

API	38.2
D86 IBP	101.0
Vapor P	10.61
C2-C4s	4.34

**Central Dunn**

API	37.6
D86 IBP	101.5
Vapor P	10.61
C2-C4s	4.16

# Rail Locations







# Testing Protocol

- Testing focused on parameters relevant to DOT hazardous material compliance
- The test slate included:
  - API Gravity
  - Flash Point by ASTM D3278
  - Initial Boiling Point (IBP) by ASTM D86
  - Vapor Pressure by ASTM D6377 at 37.8°C (100°F) \*
  - Light Ends Analyses by IP344
  - High Temperature Simulated Distillation (HTSD) by ASTM D7169

\* Results about 1 psi higher than if D323 RVP test method is used





## Class 3 Flammable Liquid, Packing Group I or II

- Defined by Hazardous Materials Regulations (HMR) as having the characteristics:
  - Material is a liquid at 68 °F (room temp.)
  - Material has Vapor Pressure <43.5 psig at 122 °F
  - Flashpoint <75 °F and:
    - Initial boiling point >95 °F - Packing Group II
    - Initial boiling point < or =95 °F - Packing Group I
  - Bakken = Flammable Liquid, PG I or II





# Lab Result Summary

Sample Date Range Total (152 Samples)	3/25 to 4/24/2014		
	Avg	Min	Max
Ambient Temp (°F)*	34	10	65
API Gravity	41.0	36.7	46.3
Vapor Pressure (PSI)	11.7	8.9	14.4
D86 IBP (°F)	99.5 (PG II)	91.9 (PG I)	106.8 (PG II)
Light Ends (C2-C4s)	5.48	3.52	9.30
Rail (49 Samples)			
	Avg	Min	Max
Ambient Temp (°F)*	29	10	47
API Gravity	41.7	39.2	44.0
Vapor Pressure (PSI)	11.5	9.6	12.9
D86 IBP (°F)	100.3 (PG II)	96.7 (PG II)	104.1 (PG II)
Light Ends (C2-C4s)	4.95	3.91	6.44
Well (103 Samples)			
	Avg	Min	Max
Ambient Temp (°F)*	36	11	65
API Gravity	40.6	36.7	46.3
Vapor Pressure (PSI)	11.8	8.9	14.4
D86 IBP (°F)	99.1 (PG II)	91.9 (PG I)	106.8 (PG II)
Light Ends (C2-C4s)	5.76	3.52	9.30

← API/Vapor Pressure  
Typical For Light  
Crude

Rail Cars Used Rated  
For 100 PSI Transport

← Packing Group  
Crude Currently  
Categorized/  
Transported as  
Expected

\*Some later samples missing  
Ambient Temp readings, may  
skew results colder





# Bakken Characteristics (Mar-Apr 2014)

- Average API Gravity of 41°
  - Consistent as a light crude oil
- Average Vapor pressure 11.5-11.8 psig
  - 61% below regulatory threshold
- Flashpoint <73°F
  - Consistent for flammable liquid, Packing Group I or II
- Initial Boiling Point midpoint 95°F
  - Consistent for flammable liquid, Packing Group I or II
- Low H<sub>2</sub>S & Total Acid Number (TAN)
  - No corrosivity





## Class 3 Flammable Liquid, Packing Group I or II

- Defined by Hazardous Materials Regulations (HMR) as having the characteristics:
  - Material is a liquid at 68°F (room temperature)
  - Material has Vapor Pressure <43.5 psig at 122°F
  - Flashpoint <75°F and:
    - Initial boiling point >95°F - Packing Group II
    - Initial boiling point < or =95°F - Packing Group I
  - Bakken = Flammable Liquid, PG I or II





## Class 3 Flammable Liquid, Packing Group I or II

- Defined by Hazardous Materials Regulations (HMR) as having the characteristics:
  - Material is a liquid at 68 °F (room temp.)
  - Material has Vapor Pressure <43.5 psig at 122 °F
  - Flashpoint <75 °F and:
    - Initial boiling point >95 °F - Packing Group II
    - Initial boiling point < or =95 °F - Packing Group I
  - Bakken = Flammable Liquid, PG I or II







## Class 3 Flammable Liquid, Packing Group I or II


- Defined by Hazardous Materials Regulations (HMR) as having the characteristics:
  - Material is a liquid at 68 °F (room temp.)
  - Material has Vapor Pressure <43.5 psig at 122 °F
  - Flashpoint <75 °F and:
    - Initial boiling point >95 °F - Packing Group II
    - Initial boiling point < or =95 °F - Packing Group I
  - Bakken = Flammable Liquid, PG I or II





# Vapor Pressure

- BKN Average Vapor pressure 11.5-11.8 psig (Mar-Apr)
  - 61% below regulatory threshold
- Seasonality (Rail terminal data outside control data set)





# Vapor Pressure Seasonality

- While there is some variability to the data, it shows seasonal variation over a narrow range: 8 psi to 11 psi
- This is exactly as would be expected, with a predictable pattern of higher vapor pressure in the winter and lower vapor pressures in the hotter summer months
- Over this entire 7-month period, there are no unusually high values
- This study demonstrates a predictable, consistent crude oil stream





# SGS/Intertek Round Robin Testing

- Three labs\* tested four identical Bakken crude samples for the following:
  - API Gravity by ASTM D5002
  - Vapor Pressure of Crude at 37.8° C (100° F), 4:1 V/L Ratio, by ASTM D6377
  - Initial Boiling Point (IBP) by ASTM D86 distillation

\*Two in North Dakota and one in Louisiana





# Round Robin Testing - Summary

- Excellent agreement on API Gravity and Vapor Pressure
  - Supports sample integrity maintained throughout transport and good lab performance
- Poor agreement on D86 IBP
  - Results for the same sample in each case fall on either side of the 95 ° F level used for PG I/PG II determination
  - Underscores shortcomings of tests required by PHMSA
  - API committee studying this, as well as alternatives



# Results – D86 IBP

- All samples fall within Class 3 – Either PG 1 or 2
  - Shipped on same rail cars, same EMS response
- PHMSA prescribed methodology may not be optimal test for crude oil
  - Not designed for wide boiling range materials like crude oil
  - As a result, poor agreement on Packing Group determination

## D86 IBP (°F)

Sample Location	Date @ Time	Intertek Mandan	SGS St. Rose	SGS Williston	Max Delta
1	5/1/14 @ 16:30	89.9	95.4	101.8	11.9
2	5/1/14 @ 16:30	83.1	89.1	102.6	19.5
3	4/30/14 @ 16:00	87.8	90.7	105.5	17.7
4	5/1/14 @ 16:30	89.2	94.5	102.2	13.0







# Is Bakken corrosive?

- HMR defines corrosive material
  - Corrode steel or aluminum at rate of 0.25 inch per year
  - Bakken average sulfur is  $<0.10$ , low TAN
  - Bakken is not corrosive





# Consistent Quality – Rail vs. Well

- Quality is consistent between well and rail
- Indicates there is **no spiking** of crudes before shipment

	Well	Rail
API Gravity	40.6	41.7
D86 IBP (°F)	99.1	100.3
Vap P D6330 (PSI)	11.8	11.5
<b>Light Ends %</b>		
Ethane	0.24	0.23
Propane	1.63	1.40
Isobutane	0.66	0.58
n-Butane	3.18	2.75
n-Pentane	2.92	2.72
C2-C4s	5.76	4.95
C2-C5	10.22	9.10

SimDist (°F)	Well	Rail
IBP	<97	<97
5%	107	114
10%	155	166
20%	233	239
30%	312	317
40%	396	397
50%	483	483
60%	574	574
70%	673	672
80%	787	789
90%	936	943
95%	1055	1061
FBP	1271	1278





# Loading vs. Destination Testing

- 5 Railcars loaded in North Dakota - Discharged at St. James, Louisiana

Test	Units	Avg. ND Rail Terminal Car Samples	Avg. St. James Rail Terminal Car Samples	Avg. NDPC
				Data for Same Rail Terminal
VPCR 4 (37.8° C)	psi	10.47	10.61	10.45
IBP	°F	94.7	90.4	101.7
Flash Point	°F	<50	<50	<73
H2S in Vapor Phase	ppm v/v	<1	<1	
C2-C4s	Vol %	4.00	4.08	4.23
C2-C5s	Vol %	8.01	7.89	8.13





# Key Findings

- Quality is very consistent
  - Both well-to-well and throughout the supply chain
  - Little variation throughout entire basin
  - Shows no “spiking” with NGL’s before rail shipment
  - No practical changes in quality during transit
- Very desirable to refiners
  - High gasoline, jet fuel and diesel yields
  - Very low TAN and metals/ConCarbon contents
- Produced for over 60 years
  - Recently passed one billion barrel mark
  - Moved by rail, pipeline, truck





# Key Findings (continued)

- PHMSA mandated IBP test (D86) appears not to be the optimal test method for PG determination
  - Significant variability between labs on same sample
  - Not designed for wide boiling range material like crude oil
  - Other groups, including API, are working on recommendations





# Remaining Work

- Analyze operating conditions/quality data
  - Ambient Temperatures
  - Separator and treater temps and pressures
  - Production rates/last movements out of tank
  - Tank heights
  - Vapor capture status
- Develop field operating standards at well site operations
- Final Report to be issued in late June
- Establish BKN Benchmark







# Establish BKN Benchmark

- Define BKN specifications
- Value:
  - Create reference point for buyers and sellers
  - Producers will follow specific field standards to meet BKN specs
  - Ensure proper BKN oil characterization, now and future





NORTH DAKOTA  
PETROLEUM  
COUNCIL

*We keep North Dakota going strong*



# Discussion and Questions?



NORTH DAKOTA  
PETROLEUM  
COUNCIL